bcc: J. Endler, M. Gerstman, D. Meyers

File WTC 113.00
M & O

A-49

August 1, 1969

Mario & DiBono
136 Liberty Street
New York, N.Y. 10006

Re: WTC 113.00
Spray-on Fireproofing

Gentlemen:

Please be advised that the sample submitted of Cafco Blaze Shield Type D Spray-on Fireproofing has been approved.

However, the sample of Cafco Blaze Shield Type D with Mark II coating has been disapproved by the Architect as "Spec calls for Mark III". There is a definite discrepancy in the specification as Page 122, par. 13.01, A, 4, calls for Mark II hard finish, and on Page 127, par. 13.09, 2, B, the specification calls for sample panels with Cafco Mark III overspray. We believe, and are pursuing our assumption, that the Mark III is a misprint, and we are awaiting confirmation.

We will advise you upon receipt of this information.

Very truly yours,

Tishman Realty & Construction Co., Inc. (Agent)

D. Meyers
Arch. Coordinator

DM:cm

cc-R. Monti, F. Werneke, P/A

PLAINTIFF'S EXHIBIT
PX-619